



**RICHARDS LANDING
DRINKING WATER SYSTEM
WATERWORKS # 220007212**







**ANNUAL & SUMMARY
REPORTS 2020**



Introduction

This Annual and Summary Report has been prepared in accordance with both Schedule 22 and section 11 of Ontario Regulation 170/03. In this manner, the requirements by regulation for each report have been consolidated into a single document. This Report is intended to brief the ownership and consumers of the Richards Landing Drinking Water System on the system's performance over the past calendar year January 1 to December 31, 2020.

This report encompasses all elements as required by O. Reg. 170/03. Each section explains what is required for the category Large Municipal Residential DWS (as it pertains to the Richards Landing DWS) and how limits were met or if shortfalls were revealed. The last section contains a list of tables and definition of terms identified in this report.

 System Description	Page 3
 Water Quality	Page 4
 Compliance	Page 7
 Flows	Page 8
 Report Availability	Page 10
 Tables, Definition of Terms App: A/B	Page 11



System Description

The Richards Landing Well Pump house is owned by the Township of St. Joseph.

Richards Landing is located on the northern shore of St. Joseph Island, in the Township of St. Joseph. The Well Pump house was constructed in 1994 on the corner of Highway 548 and Lewellyn Street to replace the private well systems previously used in the community of Richards Landing. The Township of St. Joseph Water Treatment facility is rated as a Class 1 Water Treatment subsystem and is categorized under O. Reg. 170/03 as a Large Municipal Residential system. Approximately 400 of the Township's 1122 residents are provided with potable drinking water from the facility.

The system is comprised of the following equipment:

- Two wells equipped with submersible pumps, one monitoring well, instrumentation and controls
- Disinfection process including two filtration trains each consisting of one 10-micron bag filter system, disinfection facilities (two UV irradiation reactors and a sodium hypochlorite chemical feed system consisting of two chemical feed pumps),
- Corrosion control process including a blended phosphate chemical feed system consisting of two chemical feed pumps
- In-ground storage, four high lift pumps and one fire pump. A diesel generator is located on-site to provide emergency power, and two pressure tanks maintain distribution system pressure during low flow conditions.

The facility design capacity is 912 L/min and the high lift pumps maintain system pressure between 87 and 99 psi (600 to 680 kPa) under normal operating conditions (maximum daily flow)

Chemicals

Chemicals utilized at the Richards Landing Treatment plant during 2020 include:

- Sodium Hypochlorite for primary and secondary disinfection
- Blended Phosphates - Carus 8500™

2020 Expenditures

During the year of 2020, expenses were incurred to maintain treatment and distribution functions:

- Repair of main break
- Purchase of UV sensor
- Purchase of spare chemical metering pump
- 12-month surveillance audit for DWQMS (SAI Global)
- ESA services

2020 Drinking Water System Changes

Form 1 – Record of Watermains Authorized as a Future Alteration

- n/a

Form 2 – Record of Minor Modification or Replacements

- n/a

Form 3 – Record of addition, modification or replacement of equipment discharging a contaminant of concern to the atmosphere

- n/a



Water Quality

Microbiological Sampling and Testing

Sampling is conducted weekly for the DWS at the frequencies and locations identified by Schedule 11 of O. Reg. 170/03 for Large Municipal Residential Systems.

Table 1: Microbiological sampling requirements

Location	Sample Analysis	# samples	Frequency
Raw	EC / TC	1 sample	weekly
Treated	N/A	1 sample	weekly
Distribution	EC / TC/ HPC-25%	8 samples	monthly

Richards Landing raw samples are collected from a sample tap from the raw water header. Treated samples are collected from a sample tap from the treated discharge header prior to distribution. Distribution samples are rotated weekly at the following locations representing areas throughout the village: 1669 Arthur, 1209 Catherine, 1211 Richards, 1250 Margarite. Other locations may be sampled as required.

Table 1a: Microbiological Sample Results

Type	# samples	EC (range)	TC (range)	# samples	HPC (range)
Raw	106	0 - 1	0 - 19	-	-
Treated	53	0	0	53	0 - 20
Distribution	106	0	0	53	0 - 40

Operational Checks and Testing

Operational testing is completed as per Schedules 6 & 7 of O. Reg. 170/03 for Large Municipal Residential Systems. These checks and testing are completed on site at the water treatment facility by licensed operators. Continuous monitoring analyzers (collecting at minimum 15-minute readings) are utilized for measurement of filter turbidity and chlorine residuals.

Table 2: Monthly Filter Turbidity Results

Month	Filter #1		Filter #2	
	Average (NTU)	Range (NTU)	Average (NTU)	Range (NTU)
January	0.16	0 - 2.04	0.17	0 - 2.03
February	0.17	0 - 2.04	0.18	0 - 2.03
March	0.14	0 - 1.43	0.19	0 - 1.96
April	0.26	0 - 2.04	0.15	0 - 1.76
May	0.26	0 - 2.04	0.15	0 - 2.03
June	0.30	0 - 1.84	0.17	0 - 1.50
July	0.13	0 - 2.04	0.16	0 - 2.03
August	0.13	0 - 2.04	0.15	0 - 2.03
September	0.22	0 - 2.04	0.15	0 - 2.03
October	0.13	0 - 2.04	0.12	0 - 2.03
November	0.15	0 - 2.04	0.12	0 - 2.03
December	0.41	0 - 2.04	0.13	0 - 2.03



Table 3: Treated Chlorine Residuals

Month	Average Chlorine Residual (mg/L)	Chlorine Residual Range (mg/L)
January	1.20	0.44 - 1.35
February	1.61	0.75 - 1.80
March	1.48	0.39 - 1.85
April	1.25	0.40 - 1.44
May	1.38	0.60 - 1.53
June	1.28	0.51 - 1.40
July	1.24	0.44 - 1.39
August	1.38	0.60 - 1.55
September	1.33	0.28 - 1.71
October	1.24	0.40 - 1.38
November	1.26	0.31 - 1.47
December	1.46	0.43 - 1.61

Chlorine residuals are continuously monitored and data is recorded at a minimum 5-minute intervals.

Chemical Sampling and Testing

Schedule 13 of O. Reg. 170/03 outlines chemical sampling regiments for Large Municipal Residential systems. Schedules 23 (inorganics) and 24 (organics) are collected every 12 months as well as sodium and fluoride every 60 months. This system requires quarterly sampling for Nitrites/Nitrates, THMs, and HAAs. Schedule 15.1 outlines the requirements for semi-annual lead testing (2 periods per year). Richards Landing Lead sampling follows the reduced sampling requirements every third year.

Table 4: Schedule 23 - Inorganics

Parameter	Sample Date	Result Value (µg/L)	Units	ODWS
Antimony	23-Jun-20	<0.5	µg/L	6
Arsenic	23-Jun-20	2	µg/L	25
Barium	23-Jun-20	17	µg/L	1000
Boron	23-Jun-20	18	µg/L	5000
Cadmium	23-Jun-20	<0.1	µg/L	5
Chromium	23-Jun-20	2	µg/L	50
Fluoride	23-Jun-20	0.12	mg/L	1.5
Mercury	23-Jun-20	<0.1	µg/L	1
Selenium	23-Jun-20	1.4	µg/L	10
Sodium	23-Jun-20	58.8	mg/L	20
Uranium	23-Jun-20	<1	µg/L	20

All results for inorganic parameters are within the maximum acceptable concentrations (MAC) of the Ontario Drinking Water Quality Standards as defined in O. Reg. 169/03. No result is above the half MAC with the exception of sodium which has an aesthetic objective (AO) of 200 mg/L but has a limit of 20 mg/L for medical reasons. Notifications are completed to MOH and the residents of the DWS.

Table 5: Nitrite/ Nitrate Results

Date	ODWS	6-Jan-20	6-Apr-20	6-Jul-20	13-Oct-20
Unit	mg/L	mg/L	mg/L	mg/L	mg/L
Nitrite	1.0	<0.01	<0.05	<0.05	<0.05
Nitrate	10	1.24	1.28	1.47	1.41

All quarterly results for Nitrites and Nitrates are well below ODWS.

Table 5a: THM/HAA Results

Date	ODWS	Q1	Q2	Q3	Q4	RAA
Unit	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L
THM	100	42.7	40.5	23	26.4	27.9
HAA	80	39.1	40	30	32	35.3

ODWS established a MAC of 80 for HAAs effective January 1, 2020.



Table 6: Schedule 24 – Organics

Parameter	Date	Result	Unit	ODWS
Alachlor	23-Jun-20	<0.198	µg/L	5
Atrazine + N-dealkylated metabolites	23-Jun-20	<0.5	µg/L	5
Azinphos-methyl	23-Jun-20	<0.149	µg/L	20
Benzene	23-Jun-20	<0.1	µg/L	5
Benzo(a)pyrene	23-Jun-20	<0.01	µg/L	0.01
Bromoxynil	23-Jun-20	<0.093	µg/L	5
Carbaryl	23-Jun-20	<2	µg/L	90
Carbofuran	23-Jun-20	<3	µg/L	90
Carbon Tetrachloride	23-Jun-20	<0.2	µg/L	5
Chlorpyrifos	23-Jun-20	<0.149	µg/L	90
Diazinon	23-Jun-20	<0.149	µg/L	20
Dicamba	23-Jun-20	<0.082	µg/L	120
1,2-Dichlorobenzene	23-Jun-20	<0.3	µg/L	200
1,4-Dichlorobenzene	23-Jun-20	<0.3	µg/L	5
1,2-Dichloroethane	23-Jun-20	<0.3	µg/L	5
1,1-Dichloroethylene (vinylidene chloride)	23-Jun-20	<0.3	µg/L	14
Dichloromethane	23-Jun-20	<1.0	µg/L	50
2-4 Dichlorophenol	23-Jun-20	<0.2	µg/L	900
2,4-Dichlorophenoxy acetic acid	23-Jun-20	<0.35	µg/L	100
Diclofop-methyl	23-Jun-20	<0.233	µg/L	9
Dimethoate	23-Jun-20	<0.149	µg/L	20
Diquat	23-Jun-20	<0.2	µg/L	70
Diuron	23-Jun-20	<8	µg/L	150

Parameter	Date	Result	Unit	ODWS
Glyphosate	23-Jun-20	<20	µg/L	280
Malathion	23-Jun-20	<0.149	µg/L	190
2-Methyl-4-Chlorophenoxyacetic Acid (MCPA)	23-Jun-20	<5.83	µg/L	100
Metolachlor	23-Jun-20	<0.099	µg/L	50
Metribuzin	23-Jun-20	<0.099	µg/L	80
Monochlorobenzene	23-Jun-20		µg/L	80
Paraquat	23-Jun-20	<0.1	µg/L	10
Pentachlorophenol	23-Jun-20	<0.3	µg/L	60
Phorate	23-Jun-20	<0.099	µg/L	2
Picloram	23-Jun-20	<0.082	µg/L	190
Polychlorinated Byphenols (PCB)	23-Jun-20	<0.06	µg/L	3
Prometryne	23-Jun-20	<0.049	µg/L	1
Simazine	23-Jun-20	<0.149	µg/L	10
Terbufos	23-Jun-20	<0.099	µg/L	1
Tetrachloroethylene	23-Jun-20	<0.3	µg/L	30
2,3,4,6-Tetrachlorophenol	23-Jun-20	<0.3	µg/L	100
Triallate	23-Jun-20	<0.099	µg/L	230
Trichloroethylene	23-Jun-20	<0.2	µg/L	5
2,4,6-Trichlorophenol	23-Jun-20	<0.2	µg/L	5
Trifluralin	23-Jun-20	<0.099	µg/L	45
Vinyl Chloride	23-Jun-20	<0.1	µg/L	2

All results for organic sampling of schedule 24 are below the MAC.



Lead Sampling: The maximum acceptable concentration for lead in drinking water is 10µg/L. This applies to water at the point of consumption since lead is only present as a result of corrosion of lead solder, lead containing brass fittings or lead pipes which are found close to or in domestic plumbing and the service connection to buildings.

Lead samples are collected during the two prescribed periods each year (December 15 – March 15 and June 15 – October 15).

Sample results revealed zero exceedances during year 2018-19, sampling relief extends to 2021.

Compliance

Adverse Water Quality Incidents

During 2020, the Richards Landing DWS reported 5 incidents of adverse water quality.

Table 7: Adverse Water Quality Incidents

Date	Incident Reported
May 25	Filter turbidity Exceedance
July 2	Sodium Exceedance
September 10	Loss of Pressure in Distribution due to main break
December 21	Filter turbidity Exceedance
December 29	Filter turbidity Exceedance

Annual Drinking Water System Inspection

The last annual DWS inspection took place on May 2, 2019 by MECP Drinking Water inspector Stephanie Robbins. Zero non-conformances and zero additional recommendations and best practice were identified.

The DWS received a final inspection rating of 100%

An inspection has been scheduled for March 2021.



Flows

The Permit to Take Water authorizes the municipality to draw water from the wells at a rate not to exceed 1,037 m³/d.

The maximum daily volume taken was 379 m³, 36.5 % of the permit limit.

Municipal Drinking Water Licence: 205-101 specifies a maximum rated flow of 1,011 m³/d.

The max flow rate reported was 300 m³/d, 29.7 % of the rated capacity.

The Richards Landing WTP treated and distributed a total of 41,123 m³ (41 ML) during the year of 2020. The average day treated flow demand was 112 m³/d, and maximum day flow was 300 m³/d on July 8, 2020.

Chart 1: 5-year Production History







Table 8: Raw and Treated Water Flows 2020

2020	Raw Water Flows					Treated Water Flows			
Month	Raw Water (m ³)	Minimum Day (m ³ /d)	Maximum Day (m ³ /d)	Average Day (m ³ /d)	% Max. Flow Day of rated Capacity	Treated Water (m ³)	Minimum Day (m ³ /d)	Maximum Day (m ³ /d)	Average Day (m ³ /d)
January	2,755	3	190	88.9	18.3	2,779	79	101	89.6
February	2,617	39	164	90.2	15.8	2,578	80	99	89.0
March	2,678	0	139	86.4	13.4	2,645	76	107	85.3
April	2,526	9	135	84.2	13.0	2,556	77	102	85.2
May	3,699	0	253	119.3	24.4	3,686	81	186	118.9
June	5,090	77	246	169.7	23.7	5,256	113	237	175.2
July	5,391	46	349	173.9	33.7	5,539	116	300	178.7
August	4,686	97	254	151.2	24.5	4,785	113	226	154.3
September	3,786	39	379	126.2	36.5	3,359	92	168	112.0
October	2,843	1	123	91.7	11.9	2,861	77	108	92.3
November	2,527	0	173	84.2	16.7	2,445	74	94	81.5
December	2,759	14	138	89	13.3	2,634	76	94	85.0

Chart 2: Richards Landing WTP Production 2020





Report Availability

Annual Report

Section 11 of O. Reg. 170/03 defines that this Annual Report must be given, without charge, to every person who requests a copy. Effective steps must also be taken to advise users of water from the system that copies of the report are available, without charge, and of how a copy may be obtained. This Annual Report shall be made available for inspection by the public on the Town Office.

Township of St. Joseph
P.O. Box 187
1669 Arthur Street
Richards Landing, Ontario Canada
P0R 1J0

Summary Report

This Summary report for The Richards Landing Drinking Water System for the period of January 1st to December 31st, 2020 has been prepared in accordance to Schedule 22 of O. Reg. 170/03.

In accordance with Schedule 22 of O. Reg. 170/03, this Summary Report has been provided to the Township of St. Joseph.



Tables, Definition of Terms

Appendix A: List of Tables/ Charts

Table 1: Microbiological sampling requirements

Table 1a: Microbiological Sample Results

Table 2: Monthly Filter Turbidity Results

Table 3: Treated Chlorine Residuals

Table 4: Schedule 23 - Inorganics

Table 5: Nitrite/ Nitrate Results

Table 6: Schedule 24 - Organics

Table 7: Adverse Water Quality Incidents

Table 8: Raw and Treated Water Flows 2020

Chart 1: 5-year Production History

Chart 2: Richards Landing WTP Production 2020

Appendix B: Definition of Terms

Acronym	Definition
AWQI	Adverse water quality incident
DWS	Drinking water system
EC	E. Coli
GUDI	Groundwater under direct influence of surface water
HAA	Haloacetic acids
HPC	Heterotrophic plate count
MAC	Maximum Acceptable Concentration
m ³	Cubic metres
m ³ /d	Cubic metres per day
mg/L	Milligram per litre (part per million)
ML	Megalitre (1,000 m ³)
MOH	Medical Officer of Health
NTU	Nephelometric turbidity unit
ODWS	Ontario Drinking Water Standards
O. Reg. 170/03	Ontario Regulation 170/03
PTTW	Permit to take water
SCADA	Supervisory control and data acquisition
TC	Total coliforms
THM	Trihalomethane
µg/L	Microgram per litre (part per billion)
WD	Water distribution
WT	Water treatment
WTP	Water treatment plant